

Certificate No. VR2-DE-2023-01 EU

The DEKRA certification body for vapour recovery systems, according to EN 16321-1
Sieker Landstraße 130, 22143 Hamburg, Germany

The testing laboratory confirms the acceptance of tests according to EN 16321-1 for the following vapour recovery system:	
Typ of system:	Active distributed vapour recovery system with variable speed pump with control via flow sensor
Nozzle:	ELAFLEX ZVA 2 GR
Hose assembly:	ELAFLEX CONTI SLIMLINE 21/8 Coax
Proportional valve:	not applicable
Control board:	ASSYTECH CPT07321/SF / CPT07321/DF in connection with flow sensor
Vapour recovery pump:	ASSYTECH VRP21/2 (Scheme 2 A/B) ASSYTECH VRP21/3 / VRP21/4 (Scheme 4 A/B)
Flow Sensor:	COPTRON CPTF07

Conditions for installation and operation: <i>Requirements to ensure system performance in use</i>	
Maximum volumetric fuel-flow rate:	38 l/min
Maximum back pressure in vapour recovery pump outlet line with maximum vapour flow:	50 mbar
Correction factor for system settings with petrol-flow of 38 l/min:	1,07

The vapour recovery system complies with the state of the art - according to Directive 2009/126/EC, as last amended by Directive 2014/99/EU.

Germany, Hamburg 11/07/2023

Expiration date for placing on the market: 01/07/2025



Test Center for gas recovery systems TC-GRSYS


Dipl. Ing. (FH) EWE Christian Bolzani

