

Certificate No. VR2-DE-2024-01 EU

The DEKRA certification body for vapour recovery systems, according to EN 16321-1
Sieker Landstraße 130, 22143 Hamburg, Germany

The testing laboratory confirms the acceptance of tests according to EN 16321-1 for the following vapour recovery system:	
Type of system:	Active distributed vapour recovery system with electronic proportional valve
Nozzle:	ELAFLEX ZV2 GR
Hose assembly:	ELAFLEX CONTI SLIMLINE 21/8 Coax
Proportional valve:	CHUNHUI EPV10
Control board:	GILBARCO VRB
Vapour recovery pump:	DÜRR MEX 0544

Conditions for installation and operation: <i>Requirements to ensure system performance in use:</i>	
Maximum volumetric fuel-flow rate:	38 l/min
Maximum back pressure in vapour recovery pump outlet line with maximum vapour flow:	50 mbar
Correction factor for system settings with petrol-flow of 38 l/min:	1,03

The vapour recovery system complies with the state of the art - according to Directive 2009/126/EC, as last amended by Directive 2014/99/EU.

Germany, Hamburg **29/07/2024**

Test Center for
gas recovery systems TC-GRSYS

Expiration date for placing
on the market: **01/08/2026**




Dipl.-Ing. (FH) EWE Christian Bolzani

