Certificate No. VR2-DE-2026-02 EU

The DEKRA certification body for vapour recovery systems, according to EN 16321-1
Sieker Landstraße 130, 22143 Hamburg, Germany

The testing laboratory confirms the acceptance of tests according to EN 16321-1 for the following vapour recovery system:	
Type of system:	Active distributed vapour recovery system with variable speed pump
Nozzle:	ELAFLEX | ZVA 2 GR
Hose assembly:	ELAFLEX | CONTI SLIMLINE 21/8 Coax
Proportional valve:	not applicable
Control board:	ASSYTECH | CPT07321/SL / CPT07321/DL
Vapour recovery pump:	ASSYTECH | VRP21/1 (Scheme 1 A/B) ASSYTECH | VRP21/3 / VRP21/4 (Scheme 3 A/B)
This is based on Certificate VR2-DE-2023-01 EU dated 11.07.2023, and the confirmation from Assytech dated 19.10.2026.	

Conditions for installation and operation: *Requirements to ensure system performance in use:*	
Maximum volumetric fuel-flow rate:	38 l/min
Maximum back pressure in vapour recovery pump outlet line with maximum vapour flow:	50 mbar
Correction factor for system settings with petrol-flow of 38 l/min:	**1,05**

The vapour recovery system complies with the state of the art - according to Directive 2009/126/EC, as last amended by Directive 2014/99/EU.

Germany, Hamburg 21/**10**/**2026**

Expiration date for placing on the market: **01**/**11**/**2028**

PRÜFSTELLE FÜR GASRÜCKFÜHRUNGSSYSTEME ZÜS TC-GRSYS

Test Center for
gas recovery systems TC-GRSYS

Dipl. Ing. (FH) Thomas Velling